

REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED BY TRANSFEROR

TRANSFEROR:

Name Straightline Construction aka Straightline Construction, L.L.C.

Address PO Box 200, Epworth, IA 52045

Number and Street or RR

City, Town or P.O.

State

Zip

TRANSFeree:

Name Zachary Allen Muller

Address 1922 Hwy 13, Manchester, IA 52057

Number and Street or RR

City, Town or P.O.

State

Zip

Address of Property Transferred:
25840 217th Ave, Delhi, IA 52223

Number and Street or RR

City, Town or P.O.

State

Zip

Legal Description of Property: (Attach if necessary) Lots Nineteen (19) and Twenty (20) of
Camp-O-Delhi, a Subdivision of the SW¼ of the SE¼ of Section 24, Township 88 North, Range 5,
West of the Fifth P.M., in Delaware County, Iowa, according to plat recorded in Book 5 Plats, Page 78.

1. Wells (check one)

☒ There are no known wells situated on this property.

☐ There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)

☒ There is no known solid waste disposal site on this property.

☐ There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

☒ There is no known hazardous waste on this property.

☐ There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

☒ There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)

☐ There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- ☒ There are no known private burial sites on this property.
☐ There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. Private Sewage Disposal System (check one)

- ☐ All buildings on this property are served by a public or semi-public sewage disposal system.
☐ This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
☒ There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
☐ There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
☐ There is a building served by private sewage disposal system on this property. The buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
☐ There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #9]
☐ This property is exempt from the private sewage disposal inspection requirements pursuant to the following exemption [Note: for exemption #9 use prior check box]: _____
☐ The private sewage disposal system has been installed within the past two years pursuant to permit number _____

Information required by statements checked above should be provided here or on separate sheets attached hereto:

**I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM
AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.**

Signature: *R. A. Thomas* Telephone No.: (563) 542-1485
(Transferor or Agent)



Time of Transfer Inspection Report

Property Information

Current Owner: Straightline Construction

Buyer: _____ Realtor: _____

Site Address/County: 25840 217th Ave Delhi, IowaLegal Description 25840 217th Ave Delhi, IowaNo. of bedrooms: 1 Last occupied: Present Records available: _____Permit/ installation date: _____ Separation distances (ok/no?): Okay

Septic System information

Septic tank(s): Size: 1750 Holding Tank Material: Concrete Condition: GoodTank pumped? XY N Date: 6/13/19 Licensed pumper: Triple J

Septic/Trash/Processing tank: Size: _____ Material: _____ Condition: _____

Tank pumped? ☐ Y ☐ N Date: _____ Licensed pumper: _____

Aerobic treatment unit (ATU) mfr _____ Size _____

Tank pumped? ☐ Y ☐ N Date: _____ Licensed pumper: _____Maintenance contract? ☐ Y ☐ N Expiration date: _____ Service provider: _____

Condition: _____

Pump tanks/vaults: Type: _____ Size: _____ Condition: _____

Distribution system: Distribution box _____ Outlets used _____ Condition: _____

Header pipe(s): _____ No. of lines: _____ Pressure dosed? _____

Secondary Treatment:

Length of absorption fields: _____ Determined by: _____

Condition of fields: _____ Determined by: _____

Type of trench material: _____

Size of sand filter: _____ Determined by: _____

Vent pipes above grade? ☐ Y ☐ N Discharge pipe located? ☐ Y ☐ NEffluent sample taken No Discharge Results: N/A

Media Filters: Type: _____

Maintenance contract? ☐ Y ☐ N Expiration date: _____ Service provider: _____

Condition: _____

NPDES General Permit No. 4: Required? ☐ Y ☐ N Permitted? ☐ Y ☐ N NOI provided: _____



Time of Transfer Inspection Report

Other components:

Alarms: ☐ Y ☐ N Working: ☐ Y ☐ N Disinfection: ☐ Y ☐ N Working: ☐ Y ☐ N

Control Box: _____ Timers: _____ Inspection Ports: _____

Other components: _____

Overall condition of the private sewage disposal system:

Report system status: _____

Explain (attach additional pages as needed): _____

Comments: System working properly at time of inspection. Holding tank only.

Site status at conclusion of Time of Transfer inspection:

- Verify that controls are set on the appropriate mode.
- Power is on to all components.
- Revisit all components to verify lids are secure.
- Gather all tools for removal from the site.
- Verify that no sewage is on the ground surface.

Using this worksheet, write a narrative report of the inspection results and attach a site sketch.

This report indicates the condition of the private sewage disposal system at the time of the inspection. It does not guarantee that it will continue to function satisfactorily.

Signature of Certified Inspector: Jason Brimeyer Date: 6-18-19

Name (print): Jason Brimeyer Certificate #: 9446

Address: 23775 Pilot Grove Rd Epworth, Iowa 52045

Phone #: 563-590-2471

Provide a copy of this report, the narrative report and sketch to the seller/agent, buyer/agent or the person ordering the inspection, the county sanitarian/environmental health office and to:

Iowa DNR Private Sewage Disposal Program 502 E 9th St Des Moines IA 50319