



Book 2021 Page 2652

Document 2021 GWH-2652 Type 53 001 Pages 5
Date 7/22/2021 Time 2:57:20PM
Rec Amt \$.00

Daneen Schindler, RECORDER/REGISTRAR
DELAWARE COUNTY IOWA

REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED BY TRANSFEROR

TRANSFEROR:

Name: Joseph J. Kennedy and Monica T. Straub
Address: 810 E. Main Street, Robins, IA 52328

TRANSFeree:

Name: Steve Houdek and Judy Houdek
Address: 10879 212th Ave, Anamosa, IA 52205

Address of Property Transferred:
24248 205th Ave, Manchester, Iowa 52057

Legal Description of Property: (Attach if necessary)

Lot Twenty Four (24) of Logan's First Subdivision of Part of the North one-half (N½) of Section Twenty Three (23), Township Eighty Eight (88) North, Range Five (5), West of the Fifth Principal Meridian, according to plat recorded in Book 4 Plats, Page 46

1. Wells (check one)

- ☒ There are no known wells situated on this property.
☐ There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)

- ☒ There is no known solid waste disposal site on this property.
☐ There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

- ☒ There is no known hazardous waste on this property.
☐ There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

- ☒ There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)
☐ There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- ☒ There are no known private burial sites on this property.
☐ There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

FILE WITH RECORDER

DNR form 542-0960 (July 18, 2012)

6. Private Sewage Disposal System (check one)

- ☐ All buildings on this property are served by a public or semi-public sewage disposal system.
- ☐ This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
- ☒ There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
- ☐ There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
- ☐ There is a building served by private sewage disposal system on this property. The buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
- ☐ There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #9]
- ☐ This property is exempt from the private sewage disposal inspection requirements pursuant to the following exemption [Note: for exemption #9 use prior check box]: _____.
- ☐ The private sewage disposal system has been installed within the past two years pursuant to permit number _____.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

**I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS
FOR THIS FORM AND THAT THE INFORMATION STATED
ABOVE IS TRUE AND CORRECT.**

Signature: _____

Telephone No.: 319 350 8834



Time of Transfer Inspection Report

Other components: _____

Alarms: ☐ Y ☐ N Working: ☐ Y ☐ N Disinfection: ☐ Y ☐ N Working: ☐ Y ☐ N

Control Box: _____ Timers: _____ Inspection Ports: _____

Other components: _____

Overall condition of the private sewage disposal system: _____

Report system status: _____

Explain (attach additional pages as needed): _____

Comments: System working properly at time of inspection.

Site status at conclusion of Time of Transfer inspection:

- Verify that controls are set on the appropriate mode.
- Power is on to all components.
- Revisit all components to verify lids are secure.
- Gather all tools for removal from the site.
- Verify that no sewage is on the ground surface.

Using this worksheet, write a narrative report of the inspection results and attach a site sketch.

This report indicates the condition of the private sewage disposal system at the time of the inspection. It does not guarantee that it will continue to function satisfactorily.

Signature of Certified Inspector: Jason Brimeyer Date: 6-7-21

Name (print): Jason Brimeyer Certificate #: 9446

Address: 23775 Pilot Grove Rd Epworth, Iowa 52045

Phone #: 563-590-2471

Provide a copy of this report, the narrative report and sketch to the seller/agent, buyer/agent or the person ordering the inspection, the county sanitarian/environmental health office and to:

Iowa DNR Private Sewage Disposal Program 502 E 9th St Des Moines IA 50319

June 3, 2021

Monica Straub

24248 205th Ave

Manchester, Iowa

Time of transfer septic system inspection at 24248 205th Ave Manchester, Iowa.

A septic system inspection was conducted at 24248 205th Ave. Manchester , Iowa on June3, 2021. The system *includes* a 1500-gallon two compartment, concrete septic tank. The tank was opened and pumped. The distribution box was dug and found to be in good shape. We ran water for 30 mins to simulate a heavy dose and the system accepted water with no backing up. The system has 2 lines that total 40ft. The leach lines were found to be dry. The system accepted water very well. The system worked at the time of inspection.



Time of Transfer Inspection Report

Property Information

Current Owner: Monica Straub

Buyer: _____ Realtor: _____

Site Address/County: 24248 205th Ave Manchester, Iowa

Legal Description 24248 205th Ave Manchester, Iowa

No. of bedrooms: 2 Last occupied: Present Records available: No

Permit/ installation date: _____ Separation distances (ok/no?): Okay

Septic System information

Septic tank(s): Size: 1500Gallon Material: Concrete Condition: Good

Tank pumped? ☒ Y ☐ N Date: 6-3-2021 Licensed pumper: Triple j

Septic/Trash/Processing tank: Size: _____ Material: _____ Condition: _____

Tank pumped? ☐ Y ☐ N Date: _____ Licensed pumper: _____

Aerobic treatment unit (ATU) mfg _____ Size _____

Tank pumped? ☐ Y ☐ N Date: _____ Licensed pumper: _____

Maintenance contract? ☐ Y ☐ N Expiration date: _____ Service provider: _____

Condition: _____

Pump tanks/vaults: Type: _____ Size: _____ Condition: _____

Distribution system: Distribution box Yes Outlets used 2 Condition: Good plastic

Header pipe(s): _____ No. of lines: _____ Pressure dosed? _____

Secondary Treatment:

Length of absorption fields: 2x20' Determined by: Probing and map

Condition of fields: Good Determined by: Load testing and no ponding

Type of trench material: 1" clean

Size of sand filter: _____ Determined by: _____

Vent pipes above grade? ☐ Y ☐ N Discharge pipe located? ☐ Y ☐ N

Effluent sample taken _____ Results: _____

Media Filters: Type: _____

Maintenance contract? ☐ Y ☐ N Expiration date: _____ Service provider: _____

Condition: _____

NPDES General Permit No. 4: Required? ☐ Y ☐ N Permitted? ☐ Y ☐ N NOI provided: _____