



Book 2023 Page 2598

Document 2023 GWH-2598 Type 53 001 Pages 4
Date 10/18/2023 Time 12:18:51PM
Rec Amt \$.00

Daneen Schindler, RECORDER/REGISTRAR
DELAWARE COUNTY IOWA

REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED IN FULL BY TRANSFEROR

If the transaction is exempt from filing a declaration of value pursuant to Iowa Code 428A.1(2), **STOP HERE**. Pursuant to Iowa Code section 558.69(1), when no declaration of value is submitted during a transaction, you are not required to submit a groundwater hazard statement or include the statutory language in Iowa Code section 558.69(8A). Please consult your realtor or legal counsel for further advice, including on whether a declaration of value is required. The Department provides this information for statutory reference only.

Instructions for this document can be found at:

<https://www.iowadnr.gov/Portals/idnr/uploads/forms/5420960%20Instructions.pdf>

Attachment 1, if required, can be found at: <https://www.iowadnr.gov/Portals/idnr/uploads/forms/5420960a.pdf>

PLEASE RETURN TO:
HAWKEYE ESCROW COMPANY
313 3RD AVE SE
CEDAR RAPIDS, IA 52401

TRANSFEROR:

Name Lee Franck, Trustee of the LaDema Fisher Vanek Trust dated September 8, 1988

Address 1045 Quinn Avenue, Stanley, Iowa 50671

Number and Street or RR

City, Town or PO

State

Zip

TRANSFeree:

Name Mitchel A. Dickson

Address 1379 132nd Street, Dundee, Iowa 52038

Number and Street or RR

City, Town or PO

State

Zip

Address of Property Transferred:

1379 132nd Street, Dundee, Iowa 52038

Number and Street or RR

City, Town or PO

State

Zip

Legal Description of Property: (Attach if necessary)

See attached Exhibit A

1. Wells (check one)

☐

No Condition - There are no known wells situated on this property.

☒

Condition Present - There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)

☒

No Condition - There is no known solid waste disposal site on this property.

☐

Condition Present - There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

- ☒ No Condition - There is no known hazardous waste on this property.
☐ Condition Present - There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

- ☒ No Condition - There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)
☐ Condition Present - There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- ☒ No Condition - There are no known private burial sites on this property.
☐ Condition Present - There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. Private Sewage Disposal System (check one)

- ☐ No Condition - All buildings on this property are served by a public or semi-public sewage disposal system.
☐ No Condition - This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
☐ Condition Present - There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
☐ Condition Present - There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
☐ Condition Present - There is a building served by private sewage disposal system on this property. The system is failing to ensure effective wastewater treatment or is otherwise improperly functioning, and the buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
☐ Condition Present - There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #7]
☒ Condition Present - There is a building served by private sewage disposal system on this property. This property is exempt from the private sewage disposal inspection requirements pursuant to the following
Exemption [Note: for exemption #7 use prior check box]: #3 - Trail
☐ Condition Present - There is a building served by private sewage disposal system on this property. The private sewage disposal system has been installed within the past two years pursuant to permit number:

Review the following two directions carefully:

- A. If you selected a box stating "No Condition" for every numbered section above, STOP HERE. Do not submit this form. Instead, pursuant to Iowa Code section 558.69(8A), you must include the following language on the first page of the recorded deed, instrument, or other writing:

"There is no known private burial site, well, solid waste disposal site, underground storage tank, hazardous waste, or private sewage disposal system on the property as described in Iowa Code section 558.69, and therefore the transaction is exempt from the requirement to submit a groundwater hazard statement."

Please consult your realtor or legal counsel for further advice on this exemption. By law, the owner of the property is responsible for the accuracy of this statement, and the Department provides this information for statutory reference only.

- B. If you checked any box stating "Condition Present" for any of the numbered sections above, continue below. You must complete this form, including providing all required information, and you must submit this form to the county recorder's office with declaration of value.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

#1 - 10 ft. west of home
Drilled Well
Active

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature: X Lee Branch trustee Telephone No.: 319-327-0197
(Transferor or Agent)

EXHIBIT A

Lot Two (2) of the Subdivision of the North one-half ($\frac{1}{2}$) of the Northeast Quarter ($NE\frac{1}{4}$) of Section Twenty Two (22), Township Ninety (90) North, Range Six (6), West of the Fifth P.M., according to plat recorded in Book A Plats, Page 10, except that part described as beginning at the Northeast corner of the Northeast Quarter ($NE\frac{1}{4}$) of said Section Twenty (22), thence North $90^{\circ} 00'$ West along the North line of said Northeast Quarter ($NE\frac{1}{4}$) four hundred sixty two and eight-tenths (462.8) feet to the point of beginning, thence continuing North $90^{\circ} 00'$ West along said North line one hundred nine and forty two hundredths (109.42) feet, thence South $45^{\circ} 00'$ West three hundred fifty (350) feet, thence South $53^{\circ} 22'$ East three hundred twenty three and forty two hundredths (323.42) feet, thence North $27^{\circ} 07'$ East three hundred twenty eight and ninety nine hundredths (328.99) feet to the Westerly right-of-way line of the existing county road, thence North $19^{\circ} 37'$ West along said right-of-way line one hundred fifty six and seventy four hundredths (156.74) feet to the point of beginning.