



Book 2024 Page 988

Document 2024 GWH-988 Type 53 001 Pages 10
Date 5/07/2024 Time 9:50:35AM
Rec Amt \$.00

Daneen Schindler, RECORDER/REGISTRAR
DELAWARE COUNTY IOWA

REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED BY TRANSFEROR

If the transaction is exempt from filing a declaration of value pursuant to Iowa Code 428A.1(2), **STOP HERE**. Pursuant to Iowa Code section 558.69(1), when no declaration of value is submitted during a transaction, you are not required to submit a groundwater hazard statement or include the statutory language in Iowa Code section 558.69(8A). Please consult your realtor or legal counsel for further advice, including on whether a declaration of value is required. The Department provides this information for statutory reference only.

Instructions for this document can be found at:

<https://www.iowadnr.gov/Portals/idnr/uploads/forms/5420960%20Instructions.pdf>

Attachment 1, if required, can be found at: <https://www.iowadnr.gov/Portals/idnr/uploads/forms/5420960a.pdf>

TRANSFEROR:

Name: R. Gene Seloover and Regina R. Seloover
Address: 27133 218th St, Earlville, IA 52041

TRANSFeree:

Name: Megan J. Merkes and Nicholas J. Merkes
Address: 321 Franklin St, Ryan, IA 52330

Address of Property Transferred:

27133 218th St, Earlville, Iowa 52041

Legal Description of Property: (Attach if necessary)

Lot Thirteen (13) of the Subdivision of Lot One (1) of Timbergate Subdivision of part of the South one-half (S 1/2) of the Southwest Quarter (SW 1/4) and part of the West one-half (W 1/2) of the Southeast Quarter (SE 1/4) of Section Thirty Six (36), Township Eighty Nine (89) North, Range Four (4), West of the Fifth Principal Meridian, according to plat recorded in Book 4 Plats, Page 39.

1. Wells (check one)



No Condition - There are no known wells situated on this property.

Condition Present - There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)



No Condition - There is no known solid waste disposal site on this property.

Condition Present - There is a solid waste disposal site on this property and information related thereto is provided in Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

- ☒ No Condition - There is no known hazardous waste on this property.
- ☐ Condition Present - There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

- ☒ No Condition - There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)
- ☐ Condition Present - There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- ☒ No Condition - There are no known private burial sites on this property.
- ☐ Condition Present - There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. Private Sewage Disposal System (check one)


- ☐ No Condition - All buildings on this property are served by a public or semi-public sewage disposal system.
- ☐ No Condition - This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
- ☒ Condition Present - There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
- ☐ Condition Present - There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
- ☐ Condition Present - There is a building served by private sewage disposal system on this property. The system is failing to ensure effective wastewater treatment or is otherwise improperly functioning, and the buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
- ☐ Condition Present - There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #7]
- ☐ Condition Present - There is a building served by private sewage disposal system on this property. This property is exempt from the private sewage disposal inspection requirements pursuant to the following Exemption [Note: for exemption #7 use prior check box]:

- ☐ Condition Present - There is a building served by private sewage disposal system on this property. The private sewage disposal system has been installed within the past two years pursuant to permit number:

A. If you checked any box stating "Condition Present" for any of the numbered sections above, continue below. You must complete this form, including providing all required information, and you must submit this form to the county recorder's office with declaration of value.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature:  Telephone No.: (319) 361-1334
(Transferor)

**TIME OF TRANSFER INSPECTION TOT# 9105 ROBB HARTER CERT # 9343****Site Information**Parcel Description: **160360101800**Address: **27133 218th Street, Earlville, IA 52041**County: **Delaware****Owner Information**Property is owned by a business: **No**

Business Name:

Owner Name: **Gene & Regina Seloover**

Email Address:

Address: **27133 218th Street, Earlville, IA 52041**

Phone No:

Site related informationNo Of Bedrooms: **3**Inspection Date: **03/11/2024**Facility Type: **Residential**Currently Occupied: **Yes**

Last Occupied:

System Installation Date:

Permit issued by County: **N/A**

Permit Number:

All plumbing fixtures enter septic system: **Yes**County contacted for records: **Yes**

Property Information Comments:

Primary Treatment**Tank**Tank Name: **Tank**Type: **Septic Tank**Tank Size (Gal): **1250**Tank Material: **Concrete**Tank Corrosion Type: **Slight**Liquid Level Type: **Normal**No. of Compartments: **2**Pump Tank Chamber: **Yes**Licensed Pumper Name: **Harter**Date Pumped: **3/11/2024**Meets Setback to Well: **Yes**Well Type: **Private**Distance To Well (Ft): **100+**Is Accessible: **Yes**Lid Intact: **Yes**Risers Intact: **Yes**Effluent Filter Present: **No**Watertight: **Yes**

Tank/Vault Pumped: **Yes** Inlet Baffle Present: **Yes** Outlet Baffle Present: **Yes** Functioning as Designed: **Yes**
Tank Comments: **This property has a shared well.**

General Primary Treatment Comments:

Distribution Type

Distribution Box

Label: Distribution Box	Material Type: Concrete	Accessible: Yes
Box Opened: Yes	Baffle Present: Yes	Speed Levelers Present: No
Watertight: Yes	Functioning As Designed: Yes	

General Distribution System Comments : **Concrete has some flaking in the d-box.**

Secondary Treatment

Lateral Field

Distribution Type: Distribution Box	Material Type: Rock and PVC Pipe	Trench Width: 24
Lines: 2	Total Length of Absorption Line: 220	System Hydraulic Loaded: Yes
Gallons Loaded: 300	Meets Setback to Well: Yes	Well Type: Private
Distance To Well (Ft): 100+	Lateral Lines Probed: Yes	Saturation or Ponding Present: No
Grass Cover Present: Yes	Lateral Lines Equal Length: Yes	System Located on Owner Property: Yes
Easement Present: N/A	Functioning as Designed: Yes	
Comments: Field is undersized for this home.		

General Secondary Treatment Comments:

Narrative Report

TOT Inspection Report Overall Narrative Comments: **System in good working condition. Concrete D-box has some flaking. Lateral field is undersized for size of residence. Well is shared with a neighbor and is over 100 feet from system. Pump tank every three years.**



TIME OF TRANSFER INSPECTION TOT# 9105 ROBB HARTER CERT # 9343


Owner Name: **Gene & Regina Seloover**

Address: **27133 218th Street , Earlville , IA 52041**


County: **Delaware**

Inspection Date: **03/11/2024**

Submitted Date: **3/12/2024**









3/2021

shared wall to NE of
property on neighbor's
property