

BK: 2026 PG: 2428
Recorded: 8/17/2026 at 10:24:25.0 AM
Pages 7
County Recording Fee: \$0.00
Iowa E-Filing Fee: \$0.00
Combined Fee: \$0.00
Revenue Tax: \$0.00
BRANDY L. MACUMBER, RECORDER
Madison County, Iowa

REAL ESTATE TRANSFER - GROUNDWATER HAZARD STATEMENT
TO BE COMPLETED IN FULL BY TRANSFEROR

If the transaction is exempt from filing a declaration of value pursuant to Iowa Code 428A.1(2), **STOP HERE**. Pursuant to Iowa Code section 558.69(1), when no declaration of value is submitted during a transaction, you are not required to submit a groundwater hazard statement or include the statutory language in Iowa Code section 558.69(8A). Please consult your realtor or legal counsel for further advice, including on whether a declaration of value is required. The Department provides this information for statutory reference only.

Instructions for this document can be found at: <https://www.iowadnr.gov/media/5465>.

Attachment 1, if required, can be found at: <https://www.iowadnr.gov/media/5466>.

TRANSFEROR:

Name	Sheryl A. Arment, Trustee of Sheryl A. Arment Revocable Trust and Brent B. Arment Trustee & Brent B. Arment Revocable Trust		
Address	3231 Windmill Rd	Ellston	IA 50074
	Number and Street or RR	City, Town or PO	State Zip

TRANSFeree:

Name	Austin Fier and Taylor Fier		
Address	2941 Homestead Ave	Lorimor	IA 50149
	Number and Street or RR	City, Town or PO	State Zip

Address of Property Transferred:

2941 Homestead Ave	Lorimor	Iowa	50149
Number and Street or RR	City, Town or PO	State	Zip

Legal Description of Property: (Attach if necessary)

The South Half (1/2) of the Southwest Quarter (1/4) of the Northeast Quarter (1/4) of Section Eight (8), in Township Seventy-four (74) North, Range Twenty-eight (28) West of the 5th P.M., Madison County, Iowa.

1. Wells (check one)

- ☒ No Condition - There are no known wells situated on this property.
☐ Condition Present - There is a well or wells situated on this property. The type(s), location(s) and legal status are stated below or set forth on an attached separate sheet, as necessary.

2. Solid Waste Disposal (check one)

- ☒ No Condition - There is no known solid waste disposal site on this property.
☐ Condition Present - There is a solid waste disposal site on this property and information related thereto is provided in

Attachment #1, attached to this document.

3. Hazardous Wastes (check one)

- ☒ No Condition - There is no known hazardous waste on this property.
- ☐ Condition Present - There is hazardous waste on this property and information related thereto is provided in Attachment #1, attached to this document.

4. Underground Storage Tanks (check one)

- ☒ No Condition - There are no known underground storage tanks on this property. (Note exclusions such as small farm and residential motor fuel tanks, most heating oil tanks, cisterns and septic tanks, in instructions.)
- ☐ Condition Present - There is an underground storage tank on this property. The type(s), size(s) and any known substance(s) contained are listed below or on an attached separate sheet, as necessary.

5. Private Burial Site (check one)

- ☒ No Condition - There are no known private burial sites on this property.
- ☐ Condition Present - There is a private burial site on this property. The location(s) of the site(s) and known identifying information of the decedent(s) is stated below or on an attached separate sheet, as necessary.

6. Private Sewage Disposal System (check one)

- ☐ No Condition - All buildings on this property are served by a public or semi-public sewage disposal system.
- ☐ No Condition - This transaction does not involve the transfer of any building which has or is required by law to have a sewage disposal system.
- ☒ Condition Present - There is a building served by private sewage disposal system on this property or a building without any lawful sewage disposal system. A certified Inspector's report is attached which documents the condition of the private sewage disposal system and whether any modifications are required to conform to standards adopted by the Department of Natural Resources. A certified inspection report must be accompanied by this form when recording.
- ☐ Condition Present - There is a building served by private sewage disposal system on this property. Weather or other temporary physical conditions prevent the certified inspection of the private sewage disposal system from being conducted. The buyer has executed a binding acknowledgment with the county board of health to conduct a certified inspection of the private sewage disposal system at the earliest practicable time and to be responsible for any required modifications to the private sewage disposal system as identified by the certified inspection. A copy of the binding acknowledgment is attached to this form.
- ☐ Condition Present - There is a building served by private sewage disposal system on this property. The system is failing to ensure effective wastewater treatment or is otherwise improperly functioning, and the buyer has executed a binding acknowledgment with the county board of health to install a new private sewage disposal system on this property within an agreed upon time period. A copy of the binding acknowledgment is provided with this form.
- ☐ Condition Present - There is a building served by private sewage disposal system on this property. The building to which the sewage disposal system is connected will be demolished without being occupied. The buyer has executed a binding acknowledgment with the county board of health to demolish the building within an agreed upon time period. A copy of the binding acknowledgment is provided with this form. [Exemption #7]
- ☐ Condition Present - There is a building served by private sewage disposal system on this property. This property is exempt from the private sewage disposal inspection requirements pursuant to the following Exemption [Note: for exemption #7 use prior check box]: _____
- ☐ Condition Present - There is a building served by private sewage disposal system on this property. The private sewage disposal system has been installed within the past two years pursuant to permit number: _____

Review the following two directions carefully:

- A. If you selected a box stating "No Condition" for every numbered section above, **STOP HERE**. Do not submit this form. Instead, pursuant to Iowa Code section 558.69(8A), you must include the following language on the first page of the recorded deed, instrument, or other writing:

"There is no known private burial site, well, solid waste disposal site, underground storage tank, hazardous waste, or private sewage disposal system on the property as described in Iowa Code section 558.69, and therefore the transaction is exempt from the requirement to submit a groundwater hazard statement."

Please consult your realtor or legal counsel for further advice on this exemption. By law, the owner of the property is responsible for the accuracy of this statement, and the Department provides this information for statutory reference only.

- B. If you checked any box stating "Condition Present" for any of the numbered sections above, continue below. You must complete this form, including providing all required information, and you must submit this form to the county recorder's office with declaration of value.

Information required by statements checked above should be provided here or on separate sheets attached hereto:

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature: *Sheryl Arment* Telephone No.: (515) 208-4722
(Transferor or Agent)

GROUNDWATER HAZARD STATEMENT

ATTACHMENT #1

NOTICE OF WASTE DISPOSAL SITE

a. Solid Waste Disposal (check one)

- ☐ There is a solid waste disposal site on this property, but no notice has been received from the Department of Natural Resources that the site is deemed to be potentially hazardous.
- ☐ There is a solid waste disposal site on this property which has been deemed to be potentially hazardous by the Department of Natural Resources. The location(s) of the site(s) is stated below or on an attached separate sheet, as necessary.

b. Hazardous Wastes (check one)

- ☐ There is hazardous waste on this property and it is being managed in accordance with Department of Natural Resources rules.
- ☐ There is hazardous waste on this property and the appropriate response or remediation actions, or the need therefore, have not yet been determined.

Further descriptive information:

I HEREBY DECLARE THAT I HAVE REVIEWED THE INSTRUCTIONS FOR THIS FORM AND THAT THE INFORMATION STATED ABOVE IS TRUE AND CORRECT.

Signature: _____ Telephone No.: (515) 208-4722
(Transferor or Agent)



IOWA DEPARTMENT OF NATURAL RESOURCES

GOVERNOR KIM REYNOLDS
LT. GOVERNOR CHRIS GOURNOYER

DIRECTOR KAYLA LYON

TIME OF TRANSFER INSPECTION TOT# 22306 MIKE HARKIN CERT # 9450

Site Information

Parcel Description: 660140826020000

Address: 2941 homestead ave, Lorimor, IA 50061

County: Madison

Owner Information

Property is owned by a business: No

Business Name:

Owner Name: Sheryl & Brent Arment

Email Address:

Address: 2941 homestead ave, Lorimor, IA 50061

Phone No:

Additional Contact Information

Name	Email Address	Affiliate Type
Sarah Cowman	cowman.sm@gmail.com	Realtor

Site related information

No Of Bedrooms: 3

Inspection Date: 07/15/2026

Facility Type: Residential

Currently Occupied: Yes

Last Occupied:

System Installation Date:

Permit issued by County: Yes

Permit Number:

All plumbing fixtures enter septic system: Yes

County contacted for records: Yes

Property Information Comments:

All plumbing fixtures appear to go into the septic system

Primary Treatment

Tank 1

Tank Name: Tank 1

Type: Septic Tank

Tank Size (Gal): 1500

Tank Material: Concrete

Tank Corrosion Type: None

Liquid Level Type: Normal

No. of Compartments: 2

Pump Tank Chamber: No

Licensed Pumper Name: Wiegert

Date Pumped: 7/15/2026 Meets Setback to Well: N/A Well Type:
Distance To Well (Ft.): Is Accessible: Yes Lid Intact: Yes
Risers Intact: Yes Effluent Filter Present: Yes Watertight: Yes
Tank/Vault Pumped: Yes Inlet Baffle Present: Yes Outlet Baffle Present: Yes Functioning as Designed: Yes
Tank Comments: 1500 cement septic tank was in good working condition

General Primary Treatment Comments:

Septic tank look like it had very little use,

Distribution Type

Distribution Box 1

Label: Distribution Box 1 Material Type: Plastic Accessible: Yes
Box Opened: Yes Baffle Present: Yes Speed Levelers Present: Yes
Watertight: Yes Functioning As Designed: Yes

General Distribution System Comments: Plastic distribution box with 4 speed levelers was functioning as designed

Secondary Treatment

Lateral Field 1

Distribution Type: Distribution Box Material Type: Leaching Chamber Trench Width: 36
Lines: 4 Total Length of Absorption Line: 400 System Hydraulic Loaded: Yes
Gallons Loaded: 250 Meets Setback to Well: N/A Well Type:
Distance To Well (Ft.): Lateral Lines Probed: Yes Saturation or Ponding Present: No
Grass Cover Present: Yes Lateral Lines Equal Length: Yes System Located on Owner Property: Yes
Easement Present: N/A Functioning as Designed: Yes
Comments: Hydraulic load the laterals all took water at time of inspection

General Secondary Treatment Comments: Probe laterals and the were all dry

Narrative Report

TOT Inspection Report Overall Narrative Comments: Septic system was in good working condition at time of inspection, this is not a guarantee for future operations



IOWA DEPARTMENT OF NATURAL RESOURCES

GOVERNOR KIM REYNOLDS
LT. GOVERNOR CHRIS COURNOYER

DIRECTOR KAYLA LYON

TIME OF TRANSFER INSPECTION TOT# 22306 MIKE HARKIN CERT # 9450

Owner Name: Sheryl & Brent Arment

Address: 2941 homestead ave , Lorimor , IA 50061

County: Madison

Inspection Date: 07/15/2026

Submitted Date: 7/17/2026

This page certifies a Time of Transfer Inspection was conducted and submitted for the property listed above in accordance with Subrule 567 IAC 69.2(8).